



Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: dfireservicetripura@gmail.com. Website: www.fireservice.tripura.gov.in

No.3-8/TFES/2022/ 2745-47

Dated, Agartala, the 17th March, 2022.

To
The Centre Superintendent,
Sabroom English Medium H.S. School,
Sabroom, South Tripura.
E-mail : sabroomengmedhs2020020@gmail.com, Cont. No. 9862089189.

Subject: - Issuance of Temporary/Provisional Fire NOC.

Sir,

With reference to your letter no. 1(32)/HM/CBSE/SEMHSS-SAB/2019-378 & 379 Dt. 23/02/2022, it is hereby certified that the building/premises has been inspected by the officer concerned of this department on 10.03.2022. In respect of implementation of Fire Safety measures, it was found that said building have not complied fully with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-IV of the latest National Building Code, 2016.

However, 03 (three) months Temporary NOC is being issued subject to fulfillment of the fire safety measures as per Fire Advisory issued vide letter No. 3-8/TFS/2020/6446-48 dated 13.07.2020.

This provision of Fire NOC shall be treated as cancelled ab initio in case the school authority fails to take fire safety measures as per recommendation of Directorate, Home (Fire & Emergency Services), Tripura, Agartala.

Issued on 17-03-2022 at Agartala.

N.B. Department is switching over offline issuance of NOC to online shortly. Therefore provisional / Temporary NOC is issued for a period of 03 (three) months. Thereafter, application to be submitted online (edistrict.tripura.gov.in) for Fire NOC.

Yours faithfully,

Joint Director,

Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to:

1. The Divisional Fire Officer, Gomati District, Udaipur, Tripura for favour of information.
2. The OC, Sabroom F&ES Station for information.